

Event Types Overview

Event types refer to the category of events that could trigger an **action** and are used primarily to create [rules](#). Event types are created on the source system and are generated in Connect by clicking **Get Latest** on the **Connectors** page. See [Generate Devices & Event Types](#) for more information.

✓ An event type is the category of activity that could occur (e.g. Alarm), while an event is the actual activity (e.g. Alarm triggered on Door E-A).

Once the event types are generated, you can add tags to group the events together and quickly select them when creating rules.

EVENT TYPES					
<input checked="" type="checkbox"/> SELECT ALL		<input type="checkbox"/> ADD TAGS		<input type="text" value=""/>	
Source System	Connector Name	Event Type Name	Event Type Tags	Event Type ID	
<input type="checkbox"/>	Lenel OnGuard	Lenel OnGuard Connector	Access Denied - Access Denied Unauthorized Arming State	Access Denied	1-22
<input type="checkbox"/>	Lenel OnGuard	Lenel OnGuard Connector	Access Denied - Access Denied: Invalid Smart Card Location	Access Denied	1-60
<input type="checkbox"/>	Lenel OnGuard	Lenel OnGuard Connector	Access Denied - No Escort Authority	Access Denied	1-47
<input type="checkbox"/>	Lenel OnGuard	Lenel OnGuard Connector	Access Denied - Reader Authority Toggle	Access Denied	1-51
<input type="checkbox"/>	Lenel OnGuard	Lenel OnGuard Connector	Access Denied - Use Limit Exceeded	Access Denied	1-12
<input type="checkbox"/>	Lenel OnGuard	Lenel OnGuard Connector	Access Granted - Access Granted No Entry Made		0-2
<input type="checkbox"/>	Lenel OnGuard	Lenel OnGuard Connector	Access Granted - Access Granted on Facility Code, No Entry Made		0-3
<input type="checkbox"/>	Lenel OnGuard	Lenel OnGuard Connector	Access Granted - Access Granted to Destination Floor		0-22
<input type="checkbox"/>	Lenel OnGuard	Lenel OnGuard Connector	Access Granted - Granted-Master		0-16
<input type="checkbox"/>	Lenel OnGuard	Lenel OnGuard Connector	Area APB - Cannot Open Door: Interlock Area Busy		3-15
<input type="checkbox"/>	Lenel OnGuard	Lenel OnGuard Connector	Area APB - Interlock Area Busy		3-13
<input type="checkbox"/>	Lenel OnGuard	Lenel OnGuard Connector	Video - Smart VMD (R)		11-2426
<input type="checkbox"/>	Lenel OnGuard	Lenel OnGuard Connector	Water - Sprinkler Bypass		26-5
<input type="checkbox"/>	Lenel OnGuard	Lenel OnGuard Connector	Water - Water Leakage Alarm		26-17

Page 1 of 10 | 1809 Rows ◀ Previous 1 | 2 | 3 | 4 | 5 ... 10 Next ▶

The Event Types page displaying a list of events from the connector system. These events are automatically created by clicking Get Latest on the Connectors page.